



THE UNIVERSITY *of* EDINBURGH

Edinburgh Research Explorer

Hybrid solar power plant with thermochemical energy storage: a multi-objective operational optimisation

Citation for published version:

Bravo, R, Ortiz, C, Chacartegui, R & Friedrich, D 2020, 'Hybrid solar power plant with thermochemical energy storage: a multi-objective operational optimisation', *Energy Conversion and Management*, vol. 205, 112421. <https://doi.org/10.1016/j.enconman.2019.112421>

Digital Object Identifier (DOI):

[10.1016/j.enconman.2019.112421](https://doi.org/10.1016/j.enconman.2019.112421)

Link:

[Link to publication record in Edinburgh Research Explorer](#)

Document Version:

Peer reviewed version

Published In:

Energy Conversion and Management

General rights

Copyright for the publications made accessible via the Edinburgh Research Explorer is retained by the author(s) and / or other copyright owners and it is a condition of accessing these publications that users recognise and abide by the legal requirements associated with these rights.

Take down policy

The University of Edinburgh has made every reasonable effort to ensure that Edinburgh Research Explorer content complies with UK legislation. If you believe that the public display of this file breaches copyright please contact openaccess@ed.ac.uk providing details, and we will remove access to the work immediately and investigate your claim.



Hybrid solar power plant with thermochemical energy storage: a multi-objective operational optimisation

R.Bravo^{a,1}, C.Ortiz^{b,c}, R.Chacartegui^d, D.Friedrich^{a,*}

^a*School of Engineering, Institute for Energy Systems, The University of Edinburgh, UK*

^b*Facultad de Física, Universidad de Sevilla, Avenida Reina Mercedes s/n, 41012, Sevilla, Spain*

^c*Departamento de Ingeniería, Universidad Loyola Andalucía, Av. de las Universidades s/n, Dos Hermanas, 41704, Sevilla, Spain*

^d*Departamento de Ingeniería Energética, Universidad de Sevilla, Camino de los Descubrimientos s/n, 41092, Sevilla, Spain*

Abstract

Energy storage is key to decarbonising the energy sector by reducing intermittency and increasing the integration of renewable energy. Thermochemical energy storage (TCES) integrated with concentrated solar and photovoltaic power plants, has the potential to provide dispatchable and competitive energy. Here we develop a multi-objective optimisation framework to find the best operational strategy of a hybrid solar power plant with a TCES system. The model uses a typical meteorological year to optimise one-year hourly operation. The results demonstrate that the integration of a calcium-looping process as TCES in a concentrated solar power plant provides dispatchability and, when hybridised with photovoltaic, enhances its competitiveness with current electricity prices. The low mismatch between supply and demand, even when a fixed commitment is required throughout the year, together with a high overall efficiency, indicates that the integration of calcium-looping in hybrid solar power plants is an opportunity to increase the penetration of solar energy in the power sector. Through the optimisation framework presented, a seasonal energy storage analysis can be developed, although a second optimisation stage is required to improve the sizing of the main components of the system in order to further reduce the energy costs.

Keywords: Calcium-looping, Thermochemical energy storage, Hybrid energy systems, Concentrated solar power, Photovoltaic systems, Multi-objective optimisation

1. Introduction

Renewable energies are key to enhance the sustainable development and decarbonisation of the power sector, and its agile implementation is required to reduce the negative effects of global warming [1]. Renewable power plants (other than hydropower) have low maintenance and operational costs [2], their carbon emissions are substantially lower compared to fossil fuel power stations [3] and their development is key to energy independence. However, these are not dispatchable (i.e. renewable power plants can dispatch energy just when the resource is available). Some renewable power plants are very competitive, where in some locations, bids for recent auctions have reached prices even below 20 $USD\ MWh^{-1}$ (mainly based on wind and solar technologies) [4].

The continuous growth in the penetration of renewable energy technologies in the power sector and the natural variability of the resource (e.g. solar, wind) adds large fluctuations in generation and large mismatches with power


demand [5]. To reduce variability and increase dispatchability of renewable power plants, the integration of energy storage allows to have control in the power dispatch [6]. Therefore, to increase the penetration of solar technologies in the power sector, the integration of energy storage is essential. On the one hand, in the case of photovoltaic systems (PV), despite the fact that the rate of projects under development is very high, the integration of electric batteries as energy storage is not economically feasible [7], but it could be competitive in the long term if the current high price of large scale electric batteries is reduced considerably [8]. On the other hand, concentrated solar power technologies (CSP) integrated with energy storage are key systems that could provide clean and dispatchable energy [9]. Furthermore, the development of CSP plants integrated with energy storage and hybridised with PV systems give solar technologies dispatchability at competitive costs [10] [11], [12]. In addition, in order to improve the dispatchability and capacity factor of solar hybrid power plants, by integrating a small fossil back-up unit, flexibility is given by allowing some carbon emissions [13], [14]. Different energy storage technologies have been proposed in concentrated solar power plants, based on three different concepts: sensible, latent and thermochemical energy storage. Sensible thermal energy storage is a mature

*Corresponding author

Email address: d.friedrich@ed.ac.uk (D.Friedrich)

¹The author is supported by a PhD student scholarship from BECAS CHILE, CONICYT.

technology used in concentrated solar power plants, which works with a temperature difference of a substance, for example, water or molten salts [15]. Latent thermal energy storage uses the heat stored or released during the phase change of a material [16]. Finally, thermochemical energy storage uses the heat of reaction of a reversible chemical reaction that absorbs and rejects energy depending on the operation [17]. Promising thermochemical energy storage technologies that can be integrated into concentrated solar power plants are the calcination-carbonation process of calcium carbonate [18], [19], or magnesium oxide [20]. Whilst TCES systems based on magnesium oxide work at lower temperatures (350-400 °C) and are considered interesting processes to use the waste heat from industrial processes [20], TCES based on calcium carbonate works at higher temperatures and is an attractive and more efficient technology to integrate into CSP plants [21]. This process is based on the following reaction that involves calcium carbonate ($CaCO_3$), calcium oxide (CaO) and carbon dioxide (CO_2):



The integration of this process, also known as calcium-looping (CaL), as a energy storage system, has several benefits. For instance, because its high energy density, a relatively small storage volume has the potential to operate as long-term energy storage, and the precursor materials used in the process, such as limestone or dolomite, are an abundant, non-corrosive, non-toxic and cheap material [18]. In order to decrease the deactivation of the material due to a multi-cyclic operation, modified materials can be used in the process [23]. In this context, [21] compares different materials and conditions to enhance the multicycle CaO conversion. Hence, the integration of a CaL process as thermochemical energy storage (TCES) technology in concentrated solar power plants is a suitable sustainable alternative to provide dispatchable power.

In order to evaluate the dispatchability of solar power plants integrated with CaL as a TCES, current studies focus on the simulation of the operation using a typical period to estimate the operation of a whole year [24], [7], for instance, one or two representative days with hourly time steps. Nevertheless, these studies suggest that a one-year with hourly time steps simulation is crucial to evaluate the operation of the solar power plant under variable solar irradiation, to consider daily and seasonal variability of the solar resource [24]. According to [25], to define the best operational strategy for a renewable energy system integrated with energy storage, an optimisation study is required, however, the storage system increase the complexity of the problem. Several studies exploit synergies between expensive but dispatchable power plants, such as CSP with thermal energy storage, integrated with affordable but intermittent renewable technologies, e.g. PV [13],

[12]. These studies, based on the application of optimisation techniques, focus on the development of operational strategies that minimises and/or maximises different key performance indicators as objective functions. In this context, [13] optimises the operation of a hybrid solar power plant integrated with thermal energy storage in the Atacama Desert, concluding that a multi-objective optimisation routine is crucial to estimate and analyse the trade-off between technical and financial performance. The focus of this research is to find the best operational strategy of a renewable power plant by maximising both the energy supplied and the dispatchability under a specific commitment, two goals that during some periods of the year are conflicting objectives.

Consequently, a multi-objective optimisation framework to model a one-year hourly operation strategy of a hybrid solar power plant with thermochemical energy storage is the main focus of the present study. Here we exploit the capacity of linear programming to optimise the annual performance of the power plant, taking into account the daily and seasonal variability of the solar resource. To reach this goal, the CaL process is modelled as mass and energy balances, where the energy balance of each subsystem depends on the temperature and the mass flow rate of the fluid. In addition, the thermodynamic properties also depend on the temperature. To simplify this non-linear model, the temperature of each process will be fixed and defined according to [24]. To handle both objectives, a linear scalarisation method is applied, as discussed in [11]. The results of this multi-objective optimisation method is a Pareto frontier that represents the trade-off between the net energy dispatched ($GWh \text{ year}^{-1}$) (that influences the levelised cost of the electricity), and the mismatch between supply and demand, estimated here through the loss of power supply capacity ($GWh \text{ year}^{-1}$), that represents the dispatchability of the power plant under a given commitment.

Abbreviations

DNI: Direct normal irradiation
 GTI: Global tilted irradiation
 TMY: Typical meteorological year
 CSP: Concentrated solar power
 CaL: Calcium-looping process
 TCES: Thermochemical energy storage
 PV: Photovoltaic
 LCOE: Levelised cost of electricity
 LPS: Loss of power supply
 SoC: State of Charge

Nomenclature

i : subscript, period (hours)
 k : subscript, material

150 DNI_i : direct normal irradiation period i
 151 GTI_i : global tilted irradiation period i
 152 A^{CSP} : solar tower heliostats field area
 153 P^{ST} : steam turbine capacity
 154 P^{MC} : main CO_2 compressor capacity
 155 P^{MT} : main CO_2 turbine capacity
 156 P^{HPSC} : high pressure CO_2 compressor capacity
 157 P^{HPST} : high pressure CO_2 turbine capacity
 158 STO^{CO_2} : CO_2 storage vessel capacity
 159 STO^{CaO} : CaO storage tank capacity
 160 STO^{Solids} : $Solids$ storage tank capacity
 161 A^{PV} : photovoltaic field area
 162 η^{opt} : optical efficiency solar field (DNI to receiver)
 163 $\eta^{receiver}$: thermal efficiency receiver
 164 P_i^{net} : net power period i
 165 E^{net} : net energy generated
 166 P_i^{demand} : power demand period i
 167 LPS_i : loss of power supply period i
 168 \hat{m}_i : molar flow rate ($kmol/s$)
 169 \dot{m}_i : mass flow rate (kg/s)
 170 \hat{h} : molar enthalpy (kJ/mol)
 171 h : enthalpy (kJ/kg)
 172 MW_i : molecular weight, component i
 173 $\Delta\hat{h}_{f,i}^0$: molar enthalpy of formation
 174 X : CaO conversion
 175

2. Methodology and Framework description

177 In this section, the modelling of a CaL thermochem-
 178 ical energy storage process, integrated in a hybrid solar
 179 power plant, is presented. Then, a multi-objective opti-
 180 misation method to define the best one-year hourly oper-
 181 ational strategy is described.

2.1. Description

182 Figure 1 represents the process involved in the gener-
 183 ation of electricity through the use of a CaL process inte-
 184 grated in a CSP and hybridised with a PV system. The
 185 CSP-CaL scheme (and nomenclature) is taken from the
 186 base case proposed in [24]. Each stream is represented by
 187 a letter and a number, where the letter defines the type
 188 of substance (g: CO_2 ; c: CaO ; s: solids $CaO + CaCO_3$),
 189 and the number indicates the position of the stream in
 190 the diagram. For the present study, a Python model has
 191 been developed to optimise the operation of a hybrid solar
 192 plant with CaL energy storage by mass and energy bal-
 193 ances. This model uses real solar irradiation as input, and
 194 by linear programming, optimises the annual hourly oper-
 195 ation of a defined power plant (CSP with CaL plus PV).
 196 Note that the current algorithm optimises the plant oper-
 197 ation and not the components sizing; hence, the capacity
 198 of each component in this study is an input to the model.
 199 The following list summarises the capacities of the main
 200 components of the power plant:

- Solar Tower field area: A^{CSP} , m^2

- Steam Turbine capacity: P^{ST} , MW
- Main CO_2 Compressor capacity: P^{MC} , MW
- Main CO_2 Turbine capacity: P^{MT} , MW
- High Pressure CO_2 Compressor capacity: P^{HPSC} , MW
- High Pressure CO_2 Turbine capacity: P^{HPST} , MW
- CO_2 Storage Vessel: STO^{CO_2} , m^3
- CaO Storage Tank: STO^{CaO} , m^3
- $Solids$ Storage Tank: STO^{Solids} , m^3
- Photovoltaic field area: A^{PV} , m^2

213 In the model, the CSP is a solar tower technology that
 214 provides heat to carry out the endothermic reaction that
 215 splits $CaCO_3$ into CaO and CO_2 at $900^\circ C$, according to
 216 equation 1. The location where this reaction takes place
 217 is known as calciner and coincides with the solar receiver.
 218 Full calcination is assumed in the model [26]. CaO exit-
 219 ing the calciner is stored at atmospheric pressure and high
 220 temperature in an insulated tank. The atmosphere inside
 221 the CaO tank is regulated by injecting an inert gas such
 222 as N_2 or He , in order to reduce the presence of CO_2 and
 223 avoid partial carbonation [21]. Nevertheless, it must be
 224 highlighted that the CaO tank for this integration with hot
 225 storage of the solids, is maintained at $900^\circ C$ and the kinet-
 226 ics of carbonation near to the equilibrium, although possi-
 227 ble, is notably slow [27], [28]. The second stream that ex-
 228 its the calciner, consisting of pure CO_2 at $900^\circ C$, first ex-
 229 changes heat in a Heat Recovery Steam Generator (HRSG)
 230 to produce electricity. Next, the CO_2 leaves the heat ex-
 231 changer and cools to approximately $40^\circ C$ to improve the
 232 efficiency of the compression process that is occurring af-
 233 terwards. After the compressor, this stream (now with a
 234 pressure of approximately 3 bar) has two possibilities:
 235 (i) it can be used in the carbonator to produce the re-
 236 versible exothermic reaction (carbonation) where it reacts
 237 with CaO from the CaO storage tank forming $CaCO_3$
 238 and releasing heat according to the previous reaction; (ii)
 239 or can be stored at high pressure in a 75 bar vessel, by
 240 using a multi-stage compressor. Then, when power needs
 241 to be dispatched, this high-pressure stream first drives a
 242 turbine to generate electricity and then mixes with the
 243 stream flowing from the power loop. This flow is heated in
 244 a regenerative system, which reaches around $654^\circ C$ and is
 245 then sent to the carbonator to drive the exothermic reac-
 246 tion described above. The storage of solids is carried out
 247 under atmospheric pressure. A mechanical conveyor sys-
 248 tem is considered here to transport the material, hence,
 249 in order to decouple the pressure between solids storage
 250 tanks (1 bar) and carbonator (3 bar), lock hoppers are
 251 used in the conveyor system[24].
 252 The CaO conversion (X) in the carbonator is highly de-
 253 pendent on the reactor conditions (pressure, temperature,
 254 % v/v CO_2) and the CaO precursor used [21]. In this
 255 work, a conservative value of $X=0.15$ is assumed. The
 256 heat released from the reaction is taken by the CO_2 that
 257 is present in excess in the carbonator. After that, this pure
 258 CO_2 stream runs a gas turbine (main turbine) to produce

electricity that is used to drive the main compressor and the surplus is dispatched to the network. The CO_2 leaves the turbine at 1 bar and approximately $700^\circ C$ and then it exchanges heat in the regenerative system to increase the temperature of the CO_2 stream before entering the carbonator. Then, the CO_2 flow described above is cooled to $40^\circ C$ to be compressed in the main compressor, closing the cycle (see figure 1).

2.2. Energy systems analysis

The following section describes the mass and energy balances used in the model for the operation of the main processes of the power plant. The main components are: solar field (heliostats and receiver), reactors (carbonator and calciner), heat exchangers, coolers, compressors and turbines. Main properties for $CaCO_3$, CaO and CO_2 are summarised in table 1. All the variables described below are non-negative real numbers unless otherwise stated.

2.2.1. Solar field:

In the solar field, each heliostat focuses the solar irradiation on the calciner that is located in the top of the solar tower (receiver). The total thermal power transferred and used in the receiver at each time step ($Q_i^{calciner}$) is calculated according equation 2.

$$Q_i^{Calciner} = DNI_i \cdot \eta_i^{opt} \cdot \eta^{receiver} \cdot A^{CSP} - Q_i^{Curtailement} \quad (2)$$

Where DNI_i is the direct normal irradiation, A^{CSP} is the total area covered by the heliostats, η_i^{opt} is the optical efficiency of the solar field that varies every hour in the model and depends on the relative position between the sun, the heliostats and the tower (including losses related to blocking, soiling, reflectance, attenuation, interception and cosine effect [29]) and $\eta^{receiver}$ is the efficiency of the receiver, which is assumed in this work as 0.85 [29]. A sensitivity analysis on this value is carried out in section 4.1. The curtailment ($Q_i^{curtailement}$) is the power that has to be curtailed when the power cycle is running at full capacity and the storage system is fully charged.

2.2.2. Calciner:

The endothermic calcination reaction occurs within the calciner, which in this case coincides with the receiver chamber located in the top of the tower. In this reactor, the stream s2, which contains calcium carbonate and calcium oxide, is heated to drive the calcination. According to [24], to achieve full calcination at atmospheric pressure and short residence times, a temperature around $900^\circ C$ is required. In the present model, fully calcination is assumed [23]. Hence, because there is no accumulation of energy in the system, nor shaft work, all the heat from the solar field is used to heat the stream s2 and complete the reaction, according to:

$$Q_i^{Calciner} = \Delta(\hat{m}_{k,i} \cdot \hat{h}_{k,i}) + \Delta \hat{h}_{r,i} \quad (3)$$

with,

$$\begin{aligned} \Delta(\hat{m}_{k,i} \cdot \hat{h}_{k,i}) &= \hat{m}_{g1,i} \cdot \hat{h}_{g1,i} + \hat{m}_{c1,i} \cdot \hat{h}_{c1,i} - \hat{m}_{s2,i} \cdot \hat{h}_{s2,i} \\ \Delta \hat{h}_{r,i} &= \hat{m}_{s2,i} \cdot \Delta \hat{H}_r^\circ \end{aligned}$$

The molar flow rate of CO_2 (stream g1) is equal to the molar flow rate of CO_2 produced in the reaction. Finally, the CaO molar flow rate (stream c1) is equal to the molar flow rate of CaO in stream s2 plus the molar flow rate of CaO produced in the reaction.

2.2.3. Heat exchangers, heaters and coolers:

In a heat exchanger, there is no energy accumulation, and if considered as adiabatic, the amount of heat transferred from the hot fluid (h) to the cold fluid (c) can be modelled by [31]:

$$\begin{aligned} \dot{m}_{h_{in},i} \cdot h_{h_{in},i} - \dot{m}_{h_{out},i} \cdot h_{h_{out},i} &= \\ \dot{m}_{c_{out},i} \cdot h_{c_{out},i} - \dot{m}_{c_{in},i} \cdot h_{c_{in},i} \end{aligned} \quad (4)$$

However, the model considers thermal efficiencies in heat exchangers. As presented in previous studies [7], electric heaters can be used as heaters to use the excess electricity when supply exceed commitment. In the case of cooler 4, the CO_2 stream exiting the recuperator HXG (g12) is cooled from $150^\circ C$ down to $40^\circ C$ and part of this heat is used to heat up the CO_2 coming from the storage (Heater 1). Heater 2 was included in the process in order to avoid a non-linear relation in the carbonator, and its electrical consumption is included in the operational electrical consumption of the power plant.

Coolers are modelled similarly to heat exchangers (no energy accumulation, no shaft work, adiabatic), the difference here is that the working fluid cools while a refrigerant is heating (air in this case). The energy balance for coolers is described as:

$$\dot{m}_{r,i} \cdot c_{p_r} \cdot \Delta T_{r,i} = \dot{m}_{h_{in},i} \cdot (h_{h_{out},i} - h_{h_{in},i}) \quad (5)$$

Where c_{p_r} is the specific heat capacity of the refrigerant ($c_{p,air} (23^\circ C, 41\% \text{ rel. humidity}) = 1.012 \text{ kJ/kg} \cdot K$ [22])

2.2.4. Superheated steam Rankine cycle:

In order to simplify the model, the turbine power output (ST) of the Rankine cycle is simulated as a linear relation with the heat absorbed in the heat recovery steam generator (HRS) according to:

$$P_i^{ST} = Q_i^{HRS} \cdot \eta^{SSRC} \quad (6)$$

where η^{SSRC} is the global efficiency from thermal to electrical power. Based on models and results analysed by using the commercial software ASPEN PLUS, an efficiency $\eta^{SSRC} = 0.268$ will be considered in this study.

In our model, the state of charge (in percentage) for each tank at the start of the operation ($i=0$) is defined as:

$$SoC_{i=0} = \begin{cases} 100\% & CaO \text{ tank} \\ 0\% & \text{Solids } (CaO + CaCO_3) \text{ tank} \\ 100\% & CO_2 \text{ vessel} \end{cases} \quad (10)$$

This means that during the operation of the first hours, the storage tanks of the thermochemical energy storage system are fully charge, which allows the plant to dispatch energy even without solar irradiation. This is just a criterion for the simulations, which has insignificant influence in the yearly results. In the operational optimisation routine, to calculate the actual net energy dispatched, it is necessary to estimate the difference between the available energy in the initial and final periods of the annual operation. To calculate this difference, an average energy density factor (ξ) is calculated as the rate between net power dispatched and CaO mass flow rate that feeds the carbonator:

$$\xi_i \left(\frac{MWh}{ton_{CaO}} \right) = \frac{P_i^{net}(MW)}{\dot{m}_{c2} \left(\frac{kg_{CaO}}{s} \right) \cdot 3600 \left(\frac{s}{h} \right) \cdot \frac{1}{1000} \left(\frac{ton}{kg} \right)} \quad (11)$$

The results of the model were analysed along the year to estimate this rate and a specific power production value of $\xi_i \approx 0.053 \text{ MWh } ton_{CaO}^{-1}$ was calculated.

2.2.8. Photovoltaic power plant:

Finally, the photovoltaic power plant converts the solar irradiation (in this case, the total irradiance received on a plane with fixed tilt) that reaches each solar module into electric power by the photovoltaic effect. In the simplified model shown in figure 1, the power flows to the inverter and then is dispatched to the grid. According the model described in [11], the total efficiency of the PV plant, from the solar irradiation to the electric power, considers the efficiency of panels and inverters, in addition with the losses related with module mismatch, connections and wiring.

2.3. Key performance indicators

In order to compare the operational strategy of different configurations based on measurable results, the following are key indicators for technical and financial performance used in this study:

- E^{net} is the total net electric energy dispatched by the power plant in one year of operation.
- LPSC is the total loss of power supply capacity during one year of operation, and LPSP is the loss of power supply probability according to:

$$LPSC = \sum LPS_i \quad (12)$$

$$LPSP = \frac{LPSC}{P_i^{Commitment} \cdot 8760} \quad (13)$$

- $E^{Commitment}$ is the electricity dispatched to fulfil the commitment.

- E^{Excess} is the electricity dispatched when the net energy exceeds the commitment (in this model there is no restriction for the maximum power dispatched).
- $E^{Curtailed}$ is the amount of energy available in the heliostat solar field that has to be curtailed when the power plant is running at full capacity and the storage tanks are fully charged.
- ΔE_{f-i} is the energy difference between the last hour and the first hour of operation. This difference is used to calculate the net electricity dispatched during one year of operation.
- \bar{P}^{Net} is the average power dispatched in one year, according to:

$$\bar{P}^{Net} = \frac{E^{Net}}{8760} \quad (14)$$

- P^{Max} is the maximum power dispatched during at least one hour, over one year of operation.
- CF^{CSP} is the capacity factor referred to the CO_2 Brayton cycle [33], where $E^{net, Brayton \text{ Cycle}}$ is the total energy dispatched by the Brayton cycle during one year of operation, and $P^{max, Brayton \text{ Cycle}}$ is the maximum power dispatched.

$$CF^{CSP} = \frac{E^{net, Brayton \text{ Cycle}}}{P^{max, Brayton \text{ Cycle}} \cdot 8760} \quad (15)$$

Two estimations for efficiencies will be calculated:

- $\eta^{CSP, Rec}$ is the efficiency of the solar tower power plant considering the energy available and used in the calciner:

$$\eta^{CSP, Rec} = \frac{\sum E_i^{Net, CSP}}{\sum Q_i^{Calciner}} \quad (16)$$

- $\eta^{CSP, DNI}$ is the overall efficiency of the solar power plant considering the solar energy available in the solar field:

$$\eta^{CSP, DNI} = \frac{\sum E_i^{Net, CSP}}{\sum DNI_i \cdot A^{CSP}} \quad (17)$$

- Levelised cost of the energy: representing the present value (considering an annual interest rate of $r = 7\%$) of the total life cycle costs (TLCC) involved in the generation of each unit of energy during the lifetime of the power plant ($N = 25$ years) [34].

$$LCOE = \frac{TLCC}{E^{Net}} \cdot \frac{r}{1 - (1 + r)^{-N}} \quad (18)$$

2.4. Operational optimisation by linear programming

The main objective of this research is to model one year of operation (8760 timesteps), considering the hourly solar resource of a typical meteorological year. In order to linearise the equations presented above, the temperatures of the processes are fixed, according to the parameters and results presented in [24], where non-linear models are used to simulate the operation of the CSP plant with CaL. In a power plant, this may be possible by the instrumentation engineering, through the definition and control of the temperatures of each process. Hence, the operational optimisation routine optimises the mass flow rate of some streams and calculate those that are dependent (because there are direct relationships between some streams) in order to optimise the hourly operation. Optimisation objectives can be defined according to user preferences, and these can be easily changed in the model. In this study, for a fixed power plant, the objectives of the operational optimisation are defined by:

- Maximisation of the net energy supplied during one year of operation (typical year), where the hourly net power dispatched is defined by:

$$P_i^{Net} = P_i^{Generated} - P_i^{Own\ consumption} \quad (19)$$

- Minimisation of the loss of power supply (LPS), which estimates the mismatch between the energy supplied and the commitment, i.e. the net power to be dispatched by the power plant, according to the following equation:

$$LPS_i = \begin{cases} P_i^{Commitment} - P_i^{Net} & , P_i^{Commitment} > P_i^{Net} \\ 0 & , \text{otherwise.} \end{cases} \quad (20)$$

2.5. Scalarisation method

In order to handle both objectives, and according to the results presented in [11], here a linear scalarisation method is implemented. The model developed in [11], which optimises the annual operation of a hybrid solar power plant with energy storage, found that the linear scalarisation method works faster than the epsilon (ϵ) constrain method, obtaining the same Pareto frontier. The only precaution is to choose a suitable scaling factor (ω) to scale the second objective (section 3.3 presents the analysis to define the value of ω for the case study described below). Therefore, the function that describes the multi-objective optimisation problem in the present study is:

$$\text{maximize} \quad \sum_{i=1}^I \{P_i^{Net} \cdot \Delta t_i - w \cdot LPS_i \cdot \Delta t_i\} \quad (21)$$

2.6. Computer system and tools

All optimisations presented in this study were performed using the following resources:

- PC: Intel Core i7-6700 CPU @ 3.4 GHz, 16 GB RAM.
- Operating system: 64-bits Windows 10 Education.
- Programming language: Python 3.5.3 [35]
- Optimisation package: Pyomo 5.6.1 [36], [37]
- Solver: Gurobi 8.1.1 [38]

3. Case Study

To evaluate the model and compare the results with published data, the power plant under analysis will be located in Seville, Spain. Here public data available for Seville is used (\approx N 37.4° W 6.2°, elevation 72 m), in the "Photovoltaic Geographical information system" (PVGIS project) of the European Commission Joint Research Centre [39].

3.1. Input data

3.1.1. Technical parameters

To run the model, the following hourly annual input data is required:

- Direct normal irradiation (DNI)
- Optical efficiency solar field (η^{opt})
- Global tilted irradiation (GTI)

In the present study, the typical meteorological year (TMY) is used as a representative year. Then, the direct normal irradiation is used to model a solar tower plant in SAM 2019 [29] to estimate the hourly optical efficiency of the heliostat field of the solar tower system. While values of hourly optical efficiency during summer days are from 0.42 to 0.6, winter day values are between 0.3 to 0.55, and the annual average value ($\bar{\eta}^{opt}$) is around 0.53. According to the previous equations and relations, the model also needs a series of technical and financial parameters. Among the technical parameters necessary to run the model are: efficiencies of each component (from [29]), thermodynamic properties of the elements (from table 1), and operational temperatures and pressures of each subsystem from [40]. In addition, the model considers thermal efficiencies and heat losses in the carbonator and heat exchangers. Storage tanks are modelled by mass balances, and heat losses are considered according to the design of the tanks, i.e. the insulation of the storage tanks is designed to achieve a heat transfer coefficient in the order of 100 W m^{-2} , and its losses are included as electrical consumption of the power plant.

3.1.2. Financial parameters

Financial parameters used in the model are investment costs (IC) and operational and maintenance costs (O&MC) of the solar tower, the CaL system and the photovoltaic system. The capital cost of the heliostat field, the solar tower and the photovoltaic system were obtained by modelling both a solar tower power plant and a photovoltaic system in SAM [29]. Then, the estimate of the total land area and cost (using a value of 25000 USD/ha) was used from these simulations. Capital costs for the calciner (here the investment cost was increased by 10% to include the connections necessary to install it in the solar tower receiver), carbonator, compressors, turbines, and other major components for the CaL system are summarised in table 2 where the average exchange rate considered was $r_{exch} = 1.18$ (EUR USD, 2018) [41]. For the calciner and carbonator, equations 2 and 22 are used to estimate the thermal power in order to calculate the scaling parameter applied in the equation for investment cost:

$$Q^{Carbonator} = Q^{Calciner} \cdot \eta^{overall,th} \quad (22)$$

where $\eta^{opt} \approx 0.53$, $\eta^{receiver} = 0.85$, $DNI_{design} = 0.95 \text{ kW/m}^2$, $Q_{curtailment} = 0$, and $\eta^{overall,th} = 0.9$.

Finally, a contingency of 7% and an EPC (engineering, procurement and construction) cost of 13% were considered [29]. In addition, to include all other components and auxiliary systems, a balance of plant of 10% was used. The last necessary input data is the hourly power that the power plant have to dispatch: P_i^{demand} . This is used to calculate the loss of power supply (LPS_i) as a metric to estimate the reliability or dispatchability of the power plant under that commitment.

3.2. Validation Aspen PlusTM

In order to validate the model, different configurations (based on [24]) were evaluated using Aspen PlusTM and optimised by our model written in Python. Table 3 compares three different cases, which shows the mass flow rate of different streams (kg s^{-1}) and the energy conversion in turbines, compressors, and heat exchangers (MW). In the table, the three sections in the first row indicate: the thermal power available in the calciner (MW_{th}), solar multiple (SM) as described in [45] and CaO conversion in the carbonator (X). As can be seen in the table, in most of the values, the difference between the values obtained through the Python and Aspen models is less than 1%.

3.3. Linear scalarisation method, definition of ω

In the present study, as shown in table 4, different optimisation routines with different ω were evaluated (according section 2.5). Table 4 shows that an $\omega = 1$ is a suitable scaling factor. This can be explained because the units of both objectives are the same and both have the same order of magnitude in each operation time step. In addition, in the present model there are no penalties or cost for energy not served. In other cases, for instance, when

the cost associated with unserved energy is greater than the cost of energy generation, a large scaling factor may be more appropriate.

3.4. Solar Power Plant Design

According figure 1, to optimise the annual operation of the power plant, the equipment sizes have to be known. This section presents a process to estimate the capacities of each main component using the equations and relationships described above. In a future study, this method will be improved by defining a second optimisation stage (similar to the design optimisation routine by genetic algorithms developed in [13]).

To establish a case study, it is necessary to define the capacities of the main components of the solar power plant. The process starts with the definition of the expected average power dispatched by the CSP+CaL system. In this case, a capacity of 15 MW is defined. Then, according to the estimated global efficiency value reported in [24] ($\eta_{CSP,Rec} = 0.321$), it is possible to estimate the average power needed in the calciner: $\bar{Q}^{calc} \approx 47 MW_{th}$. Next, using the equation 2 modified to take into account the average thermal power available in the calciner (\bar{q}^{calc}) per square meter of heliostat field, it is possible to have an estimate value for the heliostat aperture area (A^{CSP}):

$$\bar{Q}^{Calc} = A^{CSP} \cdot \bar{q}^{Calc} = 47,000 \text{ kW} \quad (23)$$

where

$$\bar{q}^{Calc} = \frac{\sum_1^{8760} \eta_i^{opt} \cdot \eta^{receiver} \cdot DNI_i}{8760} \approx 0.1089 \frac{\text{kW}}{\text{m}^2} \quad (24)$$

By using SAM [29] for the simulation of solar tower plant located in Seville, the average thermal power in the receiver per square meter of heliostat reflective area is approximately 0.1032 kW/m^2 . Hence,

$$A^{CSP} \approx 430,000 \text{ m}^2$$

Then, with this solar field aperture area, the design capacity of the calciner is calculated considering the equation given above (with $\eta^{opt} \approx 0.53$, $\eta^{receiver} = 0.85$, $DNI_{design} = 0.95$):

$$Q^{calc,design} \approx 180 MW_{th}$$

After that, in order to find the capacities of each component mentioned in section 3.4, this thermal power is used as input in the Aspen model ($Q^{calc} = 180 MW_{th}$), and the following capacities for each components were obtained:

$$P^{ST} \approx 10 \text{ MW}$$

$$P^{MC} \approx 23 \text{ MW}$$

$$P^{MT} \approx 43 \text{ MW}$$

$$P^{HPSC} \approx 10 \text{ MW}$$

$$P^{HPST} \approx 2 \text{ MW}$$

Table 2: References for estimating CaL components

Component	Scaling parameter	Investment cost (IC) in MUSD	Ref.
Calcliner	Thermal Power (MW_{th})	$IC = (13140 \cdot Q_{calc}^{0.67} \cdot 10^{-6}) \cdot r_{exch}$	[42]
Carbonator	Thermal Power (MW_{th})	$IC = (16591 \cdot Q_{carb}^{0.67} \cdot 10^{-6}) \cdot r_{exch}$	[42]
Steam power cycle	Cycle gross capacity (MW_e)	$IC = (290 + 1040) \cdot P_{max}^{ST} \cdot 10^{-6}$	[29]
Heat exchangers	area (m^2) and pressure (bar)	$IC = (2546.9 \cdot A_{HE}^{0.67} \cdot P_{HE}^{0.28} \cdot 10^{-6}) \cdot r_{exch}$	[42]
Cooling towers	Thermal Power (MW_{th})	$IC = (32.3 \cdot Q_{cool} \cdot 10^{-3}) \cdot r_{exch}$	[42]
CO_2 compressors and turbines	-	See reference for calculation procedure	[42]
CO_2 storage vessel	-	See reference for calculation procedure	[43]
Solids storage tanks	-	See references for calculation procedure	[44], [43]

Table 3: Validation Aspen PlusTM

item	unit	100MW _{th} , SM=3		33MW _{th} , SM=1		100MW _{th} , x=0.3	
		Aspen	Python	Aspen	Python	Aspen	Python
s2	kg/s	216.6	215.8	72.2	71.6	125.6	125.2
c2	kg/s	64.6	64.3	64.6	64	33.9	33.8
g9	kg/s	133.9	134	133.8	134.4	132.6	132.7
g13	kg/s	126.2	126.5	126.2	126.8	124.6	124.7
ST	MW	5.8	5.8	1.9	1.9	6.1	6.1
MC	MW	12.9	12.8	12.9	11.5	12.8	12.7
MT	MW	23.9	24	23.9	24	23.6	23.6
HPSC	MW	5.3	5.3	0	0	5.6	5.6
HPST	MW	0	0	0	0	0	0
HXG	MW	75.9	75.8	75.9	76	75	74.8
P ^{Net}	MW	8.2	8.2	11.3	12.5	9.3	9.3

Table 4: Scalarisation method

Objective	unit	$\omega = 0$	$\omega = 1$	$\omega \rightarrow \infty$
E^{net*}	GWh year ⁻¹	118.2	117.6	115.6
$LPSC$	GWh year ⁻¹	24.6	21.0	18.9

$$V_{m,i} = \frac{MW_i}{\rho_i} \quad (25)$$

$$STO^{Solids} = STO^{CaO} \cdot \left(x \cdot \frac{V_{m,CaCO_3}}{V_{m,CaO}} + (1-x) \right) \quad (26)$$

$$\approx 5735 \text{ m}^3$$

$$STO^{CO_2} = STO^{CaO} \cdot \left(x \cdot \frac{V_{m,CO_2}}{V_{m,CaO}} \right) \approx 875 \text{ m}^3 \quad (27)$$

Then, a number of storage hours can be defined to combine with the specific power production defined above, to estimate the capacity of the CaO storage tank (with $\rho_{CaO} \approx 3370 \text{ kg/m}^3$ [46], and values of porosity and packing density of solids equals to 0.5 and 0.6 respectively). For instance, with 20 hours of storage:

$$\xi_{i,P} = 0.053 \frac{MW h}{ton_{CaO}} = \frac{15 \text{ MW} \cdot 20 \text{ h}}{STO^{CaO} \cdot \rho_{CaO}}$$

$$\rightarrow STO^{CaO} \approx 5650 \text{ m}^3$$

Now, considering the following properties in the storage tanks: $\rho_{CaCO_3} \approx 2700 \text{ kg/m}^3$ [46] (porosity = 0.5) and $\rho_{CO_2} \approx 762 \text{ kg/m}^3$, a CaO conversion $X=0.15$, an estimate of the capacity in m^3 of the two other tanks can be calculated as a ratio of STO^{CaO} , where $V_{m,i}$ is the molar volume of substance i, defined as the volume occupied by one mole of component i in the storage tank or vessel, the following relationships:

Finally, according to section 2.5, the model was evaluated with $\omega = 0$ to maximise the energy dispatched and the capacities of all components indicated above. By the operational optimisation routine, it was calculated that the total net energy delivered in one year is 118.4 GWh, and the average power dispatched is 13.5 MW. Therefore, for the following calculations, the power commitment will be defined as $P_i^{commit} = 13.5 \text{ MW}$, $\forall i$.

4. Results and Analysis

To compare the results of different designs, nine configurations were analysed, which are summarised in table 5. The estimated capacities above are shown as "Base Case" configuration. The columns of table 5 show the name given to the configuration (Base Case, A to H), then the aperture

area of the heliostat field, the power capacity of the steam turbine, the main compressor and turbine capacities, next, the capacities of the high pressure compressor and turbine, columns 8 to 10 show the capacities of the storage tanks and finally, the photovoltaic solar field area. In each row different designs are presented, which are related to the Base Case, and all the configurations have the same aperture area of the heliostat field. For example, in configuration A the capacity of each component was increased by 20%, while in configuration B by 50%. Compressors and turbines of configuration C increased by 50% and storage remains the same. Capacities of the storage systems in configuration D were multiplied by 3. Configuration E, F, G and H are similar to B (50% increase in the capacity of each component), but now integrated with 10, 20, 30 and 40 hectare (1 hectare = 10,000 m²) of photovoltaic solar field area.

The results of the operational optimisation for all configurations described in table 5 are presented in table 6. This table shows all configurations and all key performance indicators mentioned in section 2.3.

First, the Base Case: according to table 6, for this configuration and considering the typical meteorological year, the total net energy delivered to the network reaches 118 GWh (97 GWh dispatched to the commitment and 21 GWh surplus sent to the grid), and 18% of the commitment is not supplied. 52 GWh_{th} have to be curtailed in the solar field, and the difference between the initial and the final hour of operation was 220 MWh (equivalent to approximately 16 hours fulfilling the 13.5 MW commitment). The average net power was 13.4 MW, while the maximum power dispatched by the system was 22 MW. The capacity factor is 65%, and it is highly dependent on the capacity of the main components. As a comparison, a capacity factor of 58% was estimated by [33] for a CSP with 16 hours of TCES. In a future work, the capacity factor of this hybrid solar power plant would be improved by the optimisation of the size of the units. The efficiency based on the energy used in the receiver is 32.8% (compared with 32.1 estimated by [24]), and the efficiency based on direct normal irradiation falls to 12.2%. Finally, the estimated investment is 323 MUSD and the operational and maintenance costs are 1.9 MUSD per year, resulting in a levelised cost of energy of 252 USD MWh⁻¹.

Comparing the Base Case with configuration A, the results indicate that by increasing the capacities of all components by 20%, the net energy increases by 11% and the curtailment is reduced by 76%, improving the global efficiency based on the DNI. The LPSP still exceeds 15%, and although the investment increase by 2%, the LCOE is reduced by 7%. Then, configuration B (which increases all capacities by 50%), resulted in zero curtailment, which means that in this configuration, the design of the CSP-CaL is oversized. The previous results show the key importance of selecting a certain equipment size for the plant efficiency, which is out of the scope of the present paper, but will be addressed in a future optimisation study.

When comparing configurations B, C and D, it is possible to note that, starting with the Base Case, an increase in the capacity of compressors and turbines results in more energy dispatched but a lower dispatchability and capacity factor compared with increasing the storage tank capacities, nevertheless, a better approximation to an optimal design would be by an appropriate and independent sizing of all units. Therefore, this enhances the importance of including a second optimisation stage in order to find the best design based on technical and financial performances. Finally, configurations E, F, G and H show that the integration of a photovoltaic system is important to reduce the levelised cost of the energy, by including intermittent (non-dispatchable) but less expensive power generation. In these cases, the LCOE becomes less than 200 USD MWh⁻¹. However, the integration of PV without a reduction in the capacities of the CSP-CaL system means a large energy generation and a large surplus that have to be dispatched to the network. For instance, in configuration G, which includes 30 hectare of PV modules, the energy dispatched to fulfil the commitment is 111 GWh (47% of total) while the excess of energy that have to be sent to the grid reaches 124 GWh (53% of total). In this case, it is possible that the dispatch of the surplus has negative effects on the local market, and that, depending on the mechanisms of the market, the energy may not be sold at a competitive price.

In order to know the power flow profiles of a hybrid solar power plant with thermochemical energy storage, figures 2a and 2b show two weeks of operation of configuration G, one week in summer and another in winter along with the solar resource. The continuous purple line and the dashed black line show the solar irradiation (direct normal and global tilted respectively), for the location under study. The green and orange bars of the diagrams represent the power dispatched by the PV system and the CSP-CaL respectively. These results highlight that in the case of a hybrid solar power plant composed of CSP-CaL and PV, the strategy suggested by the optimisation routine is that the photovoltaic system delivers energy during the day, while the CSP-CaL stores energy to be dispatched during the night, unless there is a large solar irradiation available that allows the CSP-CaL to dispatch energy during day and night (in the case of summer). In addition, these results demonstrate the importance of the multi-objective optimisation technique presented. The diagram confirms that during winter and cloudy summer days, the CSP-CaL dispatch energy following both objectives, maximising the energy delivered, and fulfilling the commitment. Another crucial finding, shown in the diagram as a dashed red line, is the state of charge of the CaO storage tank. Because the state of charge of the storage never reaches 0% during the week presented for the summer, and despite that there is no restriction in the maximum capacity that can be dispatched, it could be inferred that the storage system is oversized compared with the capacities of compressor and turbines. Besides, the operation profile during win-

ter suggests that there are some capacities that could be increased in the CSP-CaL system in order to increase the dispatchability of the hybrid plant.

4.1. Sensitivity Analysis

In this last section, a sensitivity analysis will be carried out by varying different financial and technical parameters, as well as the design of some of the components of configuration G presented in table 6. The parameters selected for the sensitivity analysis and its original values are:


$$\begin{aligned}\eta^{receiver} &= 0.85, \text{ efficiency receiver-calciner} \\ r &= 7\%, \text{ annual interest rate} \\ A^{PV} &= 30,000 \text{ m}^2, \text{ area photovoltaic field} \\ \kappa^{Sto} &= 1, \text{ multiplier capacities storage tanks} \\ \kappa^{T\&C} &= 1, \text{ multiplier capacities turbines and compressors} \\ \zeta^{Reactors} &= 1, \text{ multiplier investment carbonator and calciner}\end{aligned}$$

In this case, because the analysis covers financial and technical parameters, appropriate key performance indicators are the levelised cost of the energy (LCOE) and the loss of power supply probability (LPSP) (see section 2.3). Figures 3a and 3b show the sensitivity analysis for the LCOE and LPSP by varying the parameters described above between minus 10% and plus 10% from the original value reported. Figure 3a indicates that the parameters that have the largest influence on the LCOE are the efficiency of the calciner, the interest rate, and the investment cost of reactors. The efficiency of the calciner increases the thermal energy available in the endothermic reaction and the total energy dispatched, for instance, if $\eta^{receiver}$ is increased by 5% ($\eta^{receiver} \approx 0.89$), the LCOE decreases by 3%. Moreover, the configuration of the cycle could integrate different components to increase the cycle efficiency as shown in [47], in order to improve the affordability and dispatchability of the system. Next, the interest rate also has an important influence in the estimation of the LCOE, for example, if the project can be financed with a $r \approx 6.3\%$ (instead of 7%), the LCOE falls by 6%. Finally, a reduction in 10% in the capital cost of the reactors (calciner and carbonator) decreases the LCOE in 4%. This reduction is very likely to be achieved because this technology is at an early stage of maturity. Furthermore, the LCOE is highly dependent on the location of the power plant. In a future study, different regions will be analysed in order to compare key performance indicators under different solar resource and market features. For instance, if configuration G (with modifications in the solar field to keep fixed the total energy available) is analysed under the solar irradiation data corresponding to Atacama-1, a hybrid solar power plant located in Northern Chile [11], the LCOE drops to 138 USD MWh^{-1} and the LPSP reaches 0.1%. For the LPSP, by increasing any of the parameters shown in figure 3b, the energy dispatched to fulfil the commitment increases (and the LPSP decreases). Figure 3b shows


that increasing the efficiency of the calciner or the capacity of the storage is key to increase the dispatchability. Finally, the results and diagrams suggest that by increasing the storage capacities it is possible to dispatch a similar amount of energy, and when a large storage capacity is available, it is possible to manage the time when energy is dispatched, increasing the dispatchability of the power plant, allowing a long-term energy storage capacity.

5. Conclusions

This paper presents a multi-objective optimisation framework and a linearised scalarisation technique for the operation of a concentrated solar power plant with calcium-looping (CaL) as thermochemical energy storage. The model is developed with a linear programming model of the operation of the power plant validated against the software Aspen Plus. Different designs and the hybridisation with a photovoltaic system were evaluated. This contribution provides relevant information to make renewable energy systems affordable and reliable. The optimisation framework focuses on finding the best strategy of a hybrid power plant to dispatch energy during the year, and is able to report the hourly power flow profiles by each main component of the power plant, as well as the mass flow rates of each stream. In addition, this framework enables long-term studies for the optimisation of the operation of solar power plants with thermochemical energy storage and their integration into energy systems. The results summarise key performance indicators obtained by optimising the operation of a power plant located in Seville, Spain, using the solar irradiation data of the typical meteorological year as input. Among these indicators it is possible to find the total energy dispatched during the year, the mismatch between supply and demand for a given commitment, the overall efficiency of the power plant, the investment and the levelised cost of the energy. In addition, by changing the input data it is possible to optimise a similar solar power plant in any location. The findings of this study indicate that the use of a thermochemical energy storage system in concentrated solar power plants increases the dispatchability, and by hybridising with a photovoltaic system, it can become cost competitive. However, the high differences in the solar irradiation in Seville between summer and winter could have a negative effect on the power system during summer by dispatching a large amount of power during the day. Therefore, a detailed analysis of the local electrical system and its flexibility have to be analysed together with the correct design of the power plant. Our research has highlighted the importance of the multi-objective optimisation of the operation of a renewable power plant to reduce the fluctuations and maximise the energy delivered, which also influences the levelised cost of the energy. When the design of the main components of the CaL is oversized (keeping the solar field fixed), less energy



(a) Summer, 1 week



(b) Winter, 1 week

Figure 2: Optimised Operation of the hybrid solar power plant, configuration G, plus solar resource and commitment

Table 5: Different configurations analysed

Configuration name	A^{CSP} m^2	P^{ST} MW	P^{MC} MW	P^{MT} MW	P^{HPSC} MW	P^{HPST} MW	STO^{CaO} m^3	STO^{Solids} m^3	STO^{CO_2} m^3	A^{PV} m^2
Base Case	430,000	10	23	43	10	2	5650	5735	875	0
A	430,000	12	28	52	12	2.5	6780	6880	1050	0
B	430,000	15	35	65	15	3	8475	8600	1310	0
C	430,000	15	35	65	15	3	5650	5735	875	0
D	430,000	10	23	43	10	2	16950	17200	2625	0
E	430,000	15	35	65	15	3	8475	8600	1310	100,000
F	430,000	15	35	65	15	3	8475	8600	1310	200,000
G	430,000	15	35	65	15	3	8475	8600	1310	300,000
H	430,000	15	35	65	15	3	8475	8600	1310	400,000

Table 6: Operational optimisation all previous designs (table 5)

KPI	unit	Base Case	A	B	C	D	E	F	G	H
E_{net*}	GWh $year^{-1}$	118	131	137	134	124	169	202	235	268
$LPSP$	%	18	16	14	17	13	9	7	6	5
E_{commit}	GWh $year^{-1}$	97	100	101	98	103	107	110	111	112
E_{excess}	GWh $year^{-1}$	20	32	35	37	21	62	92	124	156
$E_{curtailed}$	GWh $_{th} year^{-1}$	52	13	0	9	33	0	0	0	0
ΔE_{f-i}	MWh	220	330	420	270	820	420	420	420	420
\bar{P}_{net}	MW	13.4	15.0	15.6	15.3	14.1	19.3	23.1	26.8	30.6
P_{CSP}^{max}	MW	22.0	26.6	33.2	33.2	22.0	33.2	33.2	33.2	33.2
CF_{CSP}	%	65	60	50	48	69	50	50	50	50
$\eta_{CSP,Rec}$	%	33.8	33.0	33.3	33.4	32.7	33.1	33.1	33.2	33.2
$\eta_{CSP,DNI}$	%	12.2	13.6	14.2	13.9	12.8	14.1	14.1	14.1	14.1
P_{hybrid}^{max}	MW	22.0	26.6	33.2	33.2	22.0	44.8	58.9	74.9	91.3
Investment	MUSD	323	331	341	336	341	384	427	470	513
O&M	MUSD $year^{-1}$	1.9	2.2	2.7	2.7	1.9	2.8	3.0	3.1	3.3
$LCOE$	USD MWh $^{-1}$	252	233	233	235	252	212	196	185	176

have to be curtailed, and more energy can be dispatched. However, this requires larger investments and results in lower capacity factors, therefore a proper balance between capacities and curtailed energy should be pursued. In addition, it was found that the integration of a large CaL system, which has the capacity to store a larger amount of energy, results in a significant reduction in the loss of power supply and an increase in the capacity factor. This means that a system with a large capacity to store energy can work as a medium (or even long) term energy storage. Similar to the previous point, greater energy storage capacity requires larger investment.


The hybridisation with a photovoltaic system has important effects. Because a larger solar field area is available, there is an improvement in both the energy dispatched and the loss of power supply. In addition, the operational strategy allows that, during the day the PV dispatches power while the CSP stores energy, and during the night the CSP could dispatch, reducing the mismatch between supply and demand when no solar irradiation is available. Because PV is cheaper compared with CSP, the hybridisation results in a global reduction in the levelised cost of

energy.


This study is the first step to improve the modelling and optimisation of the integration of CaL as thermochemical energy storage system in hybrid solar power plants. Currently a second stage optimisation is under development, in order to define the best capacities of the main components of the power plant by exploiting synergies related with the dispatchability of CSP-CaL and affordability of PV systems.

Acknowledgements

Ruben Bravo is supported by a PhD Scholarship from Becas Chile, National Commission for Scientific and Technological Research (CONICYT-Chile), Folio 72160177, 2015. The present research was supported by the Energy Technology Partnership (ETP), International Exchange Grants for Postgraduate and Early Career Researcher Exchanges (PECRE) 2018. Part of this project was developed within the Horizon 2020 Project Socratces, Grant Agreement 727348. Part of this work has been supported by the Spanish Government Agency Ministerio de Economia y Competitivi-



(a) Levelised cost of electricity



(b) Loss of power supply probability

Figure 3: Sensitivity analysis

dad (MINECO- FEDER funds) under contract CTQ2017-83602-C2 (-1-R and -2-R).

References

- [1] IEA, Energy Technology Perspectives 2017, International Energy Agency, Organisation for Economic Co-operation and Development (2017). doi:10.1787/energy_tech-2017-en.
- [2] NREL, System Advisor Model (SAM) (2018). URL <https://sam.nrel.gov/>
- [3] M. Pehl, A. Arvesen, F. Humpenöder, A. Popp, E. G. Hertwich, G. Luderer, Understanding future emissions from low-carbon power systems by integration of life-cycle assessment and integrated energy modelling, *Nature Energy* 2 (12) (2017) 939–945. doi:10.1038/s41560-017-0032-9.
- [4] M. Keay, D. Robinson, The limits of auctions: reflections on the role of central purchaser auctions for long-term commitments in electricity systems, Tech. rep., Oxford Institute for Energy Studies (2019). doi:10.26889/9781784671341.
- [5] P. Denholm, M. Hand, Grid flexibility and storage required to achieve very high penetration of variable renewable electricity, *Energy Policy* 39 (3) (2011) 1817–1830. doi:10.1016/j.enpol.2011.01.019.
- [6] P. Denholm, J. Jorgenson, M. Miller, E. Zhou, C. Wang, Methods for Analyzing the Economic Value of Concentrating Solar Power with Thermal Energy Storage Methods for Analyzing the Economic Value of Concentrating Solar Power with Thermal Energy Storage, Tech. Rep. July, National Renewable Energy Laboratory (2015).
- [7] R. Fernández, C. Ortiz, R. Chacartegui, J. M. Valverde, J. A. Becerra, Dispatchability of solar photovoltaics from thermochemical energy storage, *Energy Conversion and Management* 191 (2019) 237–246. doi:10.1016/j.enconman.2019.03.074.
- [8] R. Bravo, D. Friedrich, Integration of energy storage with hybrid solar power plants, *Energy Procedia* 151 (2018) 182–186. doi:10.1016/j.egypro.2018.09.045.
- [9] C. Ortiz, R. Chacartegui, J. M. Valverde, A. Alovísio, J. A. Becerra, Power cycles integration in concentrated solar power plants with energy storage based on calcium looping, *Energy Conversion and Management* 149 (2017) 815–829. doi:10.1016/j.enconman.2017.03.029.
- [10] A. Zurita, C. Mata-Torres, C. Valenzuela, C. Felbol, J. M. Cardemil, A. M. Guzmán, R. A. Escobar, Techno-economic evaluation of a hybrid CSP + PV plant integrated with thermal energy storage and a large-scale battery energy storage system for base generation, *Solar Energy* 173 (2018) 1262–1277. doi:10.1016/j.solener.2018.08.061.
- [11] R. Bravo, D. Friedrich, Two-stage optimisation of hybrid solar power plants, *Solar Energy* 164 (2018) 187–199. doi:10.1016/j.solener.2018.01.078.
- [12] M. Petrollese, D. Cocco, Optimal design of a hybrid CSP-PV plant for achieving the full dispatchability of solar energy power plants, *Solar Energy* 137 (2016) 477–489. doi:10.1016/j.solener.2016.08.027.
- [13] R. Bravo, D. Friedrich, Two-Stage, Multi-objective Optimisation Framework for an Efficient Pathway to Decarbonise the Power Sector, in: EngOpt 2018 Proceedings of the 6th International Conference on Engineering Optimization, Springer International Publishing, Cham, 2018, pp. 1420–1433. doi:10.1007/978-3-319-97773-7_122.
- [14] M. Gambini, M. Vellini, Hybrid thermal power plants: Solar-electricity and fuel-electricity productions, *Energy Conversion and Management* (2019) 682–689. doi:10.1016/j.enconman.2019.04.073.
- [15] M. Medrano, A. Gil, I. Martorell, X. Potau, L. F. Cabeza, State of the art on high-temperature thermal energy storage for power generation. Part 2-Case studies, *Renewable and Sustainable Energy Reviews* 14 (1) (2010) 56–72. doi:10.1016/j.rser.2009.07.036.
- [16] B. Zalba, J. M. Marín, L. F. Cabeza, H. Mehling, Review on thermal energy storage with phase change: Materials, heat transfer analysis and applications, *Applied Thermal Engineering* 23 (3) (2003) 251–283. doi:10.1016/S1359-4311(02)00192-8.
- [17] P. Pardo, A. Deydier, Z. Anxionnaz-Minvielle, S. Rougé, M. Cabassud, P. Cognet, A review on high temperature thermochemical heat energy storage, *Renewable and Sustainable Energy Reviews* 32 (2014) 591–610. doi:10.1016/j.rser.2013.12.014.
- [18] R. Chacartegui, A. Alovísio, C. Ortiz, J. M. Valverde, V. Verda, J. A. Becerra, Thermochemical energy storage of concentrated solar power by integration of the calcium looping process and a CO₂ power cycle, *Applied Energy* 173 (2016) 589–605. doi:10.1016/j.apenergy.2016.04.053.
- [19] P. E. Sánchez Jiménez, A. Perejón, M. Benítez Guerrero, J. M. Valverde, C. Ortiz, L. A. Pérez Maqueda, High-performance and low-cost macroporous calcium oxide based materials for thermochemical energy storage in concentrated solar power plants, *Applied Energy* (2019) 543–552. doi:10.1016/j.apenergy.2018.10.131.
- [20] C. Knoll, D. Müller, W. Artner, J. M. Welch, E. Eitenberger, G. Friedbacher, A. Werner, P. Weinberger, M. Harasek, Magnesium oxide from natural magnesite samples as thermochemical energy storage material, in: *Energy Procedia*, Vol. 158, Elsevier Ltd, 2019, pp. 4861–4869. doi:10.1016/j.egypro.2019.01.707.
- [21] C. Ortiz, J. Valverde, R. Chacartegui, L. Perez-Maqueda, P. Giménez, The Calcium-Looping (CaCO₃/CaO) process for thermochemical energy storage in Concentrating Solar Power plants, *Renewable and Sustainable Energy Reviews* 113 (2019) 109252. doi:10.1016/j.rser.2019.109252.
- [22] R. L. Jaffe, T. Washington, The physics of energy, Cambridge

- University Press, Cambridge, United Kingdom ; New York, NY, 2018. doi:10.1017/9781139061292.
- [23] J. Obermeier, K. G. Sakellariou, N. I. Tsongidis, D. Baci, G. Charalambopoulou, T. Steriotis, K. Müller, G. Karagianakis, A. G. Konstandopoulos, A. Stubos, W. Arlt, Material development and assessment of an energy storage concept based on the CaO-looping process, *Solar Energy* 150 (2017) 298–309. doi:10.1016/j.solener.2017.04.058.
- [24] C. Ortiz, M. C. Romano, J. M. Valverde, M. Binotti, R. Chacartegui, Process integration of Calcium-Looping thermochemical energy storage system in concentrating solar power plants, *Energy* 155 (2018) 535–551. doi:10.1016/j.energy.2018.04.180.
- [25] R. Renaldi, D. Friedrich, Multiple time grids in operational optimisation of energy systems with short- and long-term thermal energy storage, *Energy* 133 (2017) 784–795. doi:10.1016/j.energy.2017.05.120.
- [26] A. Meier, N. Gremaud, A. Steinfeld, Economic evaluation of the industrial solar production of lime, *Energy Conversion and Management* 46 (6) (2005) 905–926. doi:10.1016/j.enconman.2004.06.005.
- [27] C. Ortiz, J. M. Valverde, R. Chacartegui, L. A. Perez-Maqueda, Carbonation of Limestone Derived CaO for Thermochemical Energy Storage: From Kinetics to Process Integration in Concentrating Solar Plants, *ACS Sustainable Chemistry and Engineering* 6 (5) (2018) 6404–6417. doi:10.1021/acssuschemeng.8b00199.
- [28] K. Kyaw, M. Kubota, F. Vvatanabe, H. Matsuda, M. Hasatani, Study of carbonation of CaO for high temperature thermal energy storage, *Journal of Chemical Engineering of Japan* 31 (2) (1998) 281–284. doi:10.1252/jcej.31.281.
- [29] NREL, Concentrating Solar Power Projects (2017). URL <https://www.nrel.gov/csp/solarpaces/>
- [30] R. H. Perry, D. W. Green, J. O. Maloney, Perry's Chemical engineers' handbook., seventh ed Edition, McGraw-Hill, New York ; London, 1997.
- [31] I. Dincer, M. A. Rosen, P. Ahmadi, Optimization of energy systems, Wiley, 2017. doi:10.1002/9781118894484.
- [32] E. Dick, Fundamentals of Turbomachines, Vol. 109, Springer, Dordrecht, 2015. doi:10.1007/978-94-017-9627-9.
- [33] C. Ortiz, M. Binotti, M. C. Romano, J. M. Valverde, R. Chacartegui, Off-design model of concentrating solar power plant with thermochemical energy storage based on calcium-looping, in: AIP Conference Proceedings, Vol. 2126, AIP Publishing LLC, 2019, p. 210006. doi:10.1063/1.5117755.
- [34] D. Y. Goswami, Principles of solar engineering, third edit Edition, Boca Raton, FL : CRC Press, 2015.
- [35] Python Software Foundation, Python 3.5.3 (2017). URL <https://www.python.org/>
- [36] W. E. Hart, C. D. Laird, J.-P. Watson, D. L. Woodruff, G. A. Hackebeil, B. L. Nicholson, J. D. Sirola, Pyomo — Optimization Modeling in Python, Vol. 67 of Springer Optimization and Its Applications, Springer International Publishing, Cham, 2017. doi:10.1007/978-3-319-58821-6.
- [37] W. E. Hart, J. P. Watson, D. L. Woodruff, Pyomo: Modeling and solving mathematical programs in Python, *Mathematical Programming Computation* 3 (3) (2011) 219–260. doi:10.1007/s12532-011-0026-8.
- [38] L. Gurobi Optimization, Gurobi Optimizer Reference Manual (2019). URL <http://www.gurobi.com>
- [39] J. R. C. European Commission, JRC Photovoltaic Geographical Information System (PVGIS) - European Commission (2017). URL <https://re.jrc.ec.europa.eu>
- [40] C. Ortiz, J. M. Valverde, R. Chacartegui, L. A. Perez-Maqueda, Carbonation of Limestone Derived CaO for Thermochemical Energy Storage: From Kinetics to Process Integration in Concentrating Solar Plants, *ACS Sustainable Chemistry and Engineering* 6 (5) (2018) 6404–6417. doi:10.1021/acssuschemeng.8b00199.
- [41] J. Cherowbrier, • Euro to U.S. dollar exchange rate 1999-2018 — Statista (2019). URL <https://www.statista.com>
- [42] S. Michalski, D. P. Hanak, V. Manovic, Techno-economic feasibility assessment of calcium looping combustion using commercial technology appraisal tools, *Journal of Cleaner Production* 219 (2019) 540–551. doi:10.1016/j.jclepro.2019.02.049.
- [43] A. Bayon, R. Bader, M. Jafarian, L. Fedunik-Hofman, Y. Sun, J. Hinkley, S. Miller, W. Lipiński, Techno-economic assessment of solid-gas thermochemical energy storage systems for solar thermal power applications, *Energy* 149 (2018) 473–484. doi:10.1016/j.energy.2017.11.084.
- [44] M. Jonemann, Advanced Thermal Storage System with Novel Molten Salt: December 8, 2011 - April 30, 2013, Tech. rep., National Renewable Energy Laboratory (2013). doi:10.2172/1080117.
- [45] C. Ortiz, J. M. Valverde, R. Chacartegui, Energy Consumption for CO₂ Capture by means of the Calcium Looping Process: A Comparative Analysis using Limestone, Dolomite, and Steel Slag, *Energy Technology* 4 (10) (2016) 1317–1327. doi:10.1002/ente.201600390.
- [46] J. M. Valverde, P. E. Sanchez-Jimenez, L. A. Perez-Maqueda, Limestone Calcination Nearby Equilibrium: Kinetics, CaO Crystal Structure, Sintering and Reactivity, *The Journal of Physical Chemistry* (2015). doi:10.1021/jp508745u.
- [47] A. Alovisio, R. Chacartegui, C. Ortiz, J. M. Valverde, V. Verda, Optimizing the CSP-Calcium Looping integration for Thermochemical Energy Storage, *Energy Conversion and Management* 136 (2017) 85–98. doi:10.1016/j.enconman.2016.12.093.